

HDD-272, Phase III - Near JP Chowk Ring Road No.-2, Kabir Nagar, Raipur (C.G.) - 492099 Ph: 0771 - 4027777 | Email: ultimatenviro@gmail.com

Recognized by Ministry of Environment Forest and Climate Change under EP act 1996

Name & Address Of The Customer	REPORT NO.	UES/TR/22-23/05366	
To,	LAB REF NO.	UES/22-23/W/012067	
SHRI BAJRANG POWER & ISPAT LTD.	DATE OF SAMPLING	10/11/2022	
VILL: TANDAWA & KUNDRU,	DATE OF RECEIPT	11/11/2022	
DHARSIWA -TILDA ROAD ,	DATE OF REPORT	15/11/2022	
TEHSIL -TILDA, RAIPUR(C.G.)	DATE OF ANALYSIS	START: 11/11/2022	END: 15/11/2022
	SAMPLE DETAILS		

	SAMPLE DETAILS	
SAMPLE TYPE	RESERVOIR WATER	
ORDER /REFERENCE:	SBPIL/TILDA/ENV/2022-23/1404, DTD.22/10/2022	
CUSTMER SAMPLE ID	SURFACE WATER	
PACKING OF SAMPLE	4 L X 1 NO. PVC CAN, 1 L X 1 NO. GLASS BOTTLE	(SEALED)
SAMPLE COLLECTED BY	LABORATORY CHEMIST	
SAMPLING PROCEDURE	IS:3025(PART I):1987 RA 2003; APHA 22ND ED. 201.	2, 1060-B, 1-39

REPORT NO. 05366

	TEST REPORT								
SR. NO.	PARAMETER	UNIT	METHOD OF TEST	AS PER IS: 2296 TOLERANCE LIMITS FOR INLAND SURFACE WATER, CLASS-A (MAXIMUM)	RESULT				
1	Colour	Hazen	IS:3025:(Part-4)	10.0	<1.0				
2	pH Value at 25.1°C	-	IS:3025:(Part-11)	6.5 to 8.5	7.93				
3	Total Dissolved Solids	mg/L	IS:3025:(Part-16)	500.0	226				
4	Dissolved Oxygen	mg/L	IS:3025:(Part-38)	6.0	5.7				
5	Bio-chemical Oxygen Demand at 27°C for three day	mg/L	IS:3025:(Part-44)	2.0	1.3				
6	Chemical Oxygen Dissolved	mg/L	IS:3025:(Part-58)		28.0				
7	Chloride (as Cl)	mg/L	IS:3025:(Part-32)	250.0	24.9				
8	Fluoride (as F)	mg/L	IS:3025:(part-60)	1.5	0.09				
9	Iron (as Fe)	mg/L	IS:3025:(part-53)	0.3	N.D.				
10	Nitrate (as NO ₃)	mg/L	IS:3025:(part-34)	20.0	9.7				
11	Sulphate (as SO ₄)	mg/L	IS:3025:(Part-24)	400.0	21.4				
12	Lead (as Pb)	mg/L	IS:3025:(part-47)	0.1	N.D.				
13	Sodium Absorption Ratio	mg/L	IS:11624-1986; RA 2001		5.67				
14	Free Ammonia	mg/L	IS:3025:(part-34)		NIL				
15	Conductivity	μS/cm	IS:3025:(Part-14)		377.2				
16	Arsenic (as As)	mg/L	IS:3025:(part-37)	0.05	N.D.				
17	Boron (as B)	mg/L	IS:3025:(Part-57)		N.D.				
18	Total Coliform	MPN/ 100ml	IS:1622:1981:RA:2019	50	24				

Note: mg/lit.: milligram per liter, N.D.: Not Detected.

REMARKS: RESULTS ARE AS ABOVE

Terms & conditions

- The use of the report for publication, arbitration or as legal dispute is forbidden.
- Fest sample will be retained for 15 days after issue of test report unless otherwise agreed with customer.

This is for information as the party has asked for above test(s) only VT

15/11/2022 PREPARED BY



For ULTIMATE ENVIROLYTICAL SOLUTIONS

AUTHORIZED SIGNATORY

-----End of the test report-----End of the test

AN ISO: 9001:2015 / ISO: 14001:2015 / ISO 45001:2018 CERTIFIED LABORATORY