



HDD-272, Phase III - Near JP Chowk
Ring Road No.-2, Kabir Nagar, Raipur (C.G.) - 492099
Ph : 0771 - 4027777 | Email : ultimatenviro@gmail.com

Recognized by Ministry of Environment Forest and Climate Change under EP act 1996

Name & Address Of The Customer		REPORT NO.	UES/TR/22-23/05329	
To, SHRI BAJRANG POWER & ISPAT LTD. (TMT DIVISION) KHASRA NO.2/3, VILL: GONDWARA, URLA INDUSTRIAL AREA COMPLEX RAIPUR (C.G.) 493221.		LAB REF NO.	UES/22-23/AAQM/012017	
		DATE OF SAMPLING	01/11/2022	
		DATE OF RECEIPT	02/11/2022	
		DATE OF REPORT	07/11/2022	
		DATE OF ANALYSIS	START: 02/11/2022	END: 07/11/2022
SAMPLE DETAILS				
SAMPLE TYPE	EFFLUENT WATER		ORDER /REFERENCE:	SBPIL(GONDWARA)/ENV/22-23/1376 DATED: 22.10.2022
CUSTOMER SAMPLE ID	PLANT DISCHARGE WATER		SAMPLE CONDITION AT RECEIPT	OK
PACKING OF SAMPLE	3 L X 1 NO. PVC CAN 1 L X 1 NO. PVC CAN 1 L X 1 NO. GLASS BOTTLE	SEALED	SAMPLE COLLECTED BY	CHEMIST
SAMPLING PROCEDURE	IS:3025(PART I):1987 RA 2003; APHA 22ND ED. 2012, 1060-B, 1-39		QUANTITY RECEIVED	5 LTR

TEST REPORT

SR. NO.	PARAMETER	UNIT	METHOD OF TEST	THE ENVIRONMENT (PROTECTION) RULES, 1986 [SCHEDULE-VI] PART-A INLAND SURFACE WATER	RESULT
1	pH	-	IS:3025(PART-11)	5.5 to 9.0	7.23
2	Total Suspended Solids	mg/Lit	IS:3025(PART-17)	100	38.0
3	Chemical Oxygen Demand (COD)	mg/Lit	IS:3025(PART-58)	250	90
4	Biochemical Oxygen Demand (BOD)	mg/Lit	IS:3025(PART-44)	30	18.4
5	Oil & Grease	mg/Lit	IS:3025(PART-39)	10.0	1.0

Note: mg/lit.: milligram per liter.

REMARKS: RESULTS ARE AS ABOVE

Terms & conditions

- The report for publication, arbitration or as legal dispute is forbidden.
- Test sample will be retained for 15 days after issue of test report unless otherwise agreed with customer.
- This is for information as the party has asked for above test(s) only

 07/11/22 REVIEWED BY		For ULTIMATE ENVIROLYTICAL SOLUTIONS AUTHORIZED SIGNATORY
-----------------------------	--	--

-----End of the test report-----