



HDD-272, PHASE III- NEAR JP CHOWK,  
RING ROAD NO - 2, KABIR NAGAR, RAIPUR, C.G. -492099  
PH - 0771 - 4027777 /email - ultimatenviro@gmail.com

<i>Name &amp; Address Of The Customer</i>		REPORT NO	UES/TR/22-23/02534
<b>To,</b> <b>M/S SHRI BAJRANG POWER &amp; ISPAT LTD (TMT DIVISION) KHASRA NO.2/3, VILL: GONDWARA, URLA INDUSTRIAL AREA COMPLEX RAIPUR (C.G.) 493221</b>		LAB REF NO	UES/22-23/N/07141-07144
		DATE OF SAMPLING	04/04/2022 to 05/04/2022
		DATE OF REPORT	08/04/2022
SAMPLE DETAILS			
CUSTOMER REF. NO. & DATE	SBPIL(GONDWARA)/ENV/22-23/932 DATED: 31.03.2022		
MONITORING FOR	NOISE LEVEL MONITORING		
SAMPLING LOCATION	INSIDE PLANT (AS DESCRIBED BELOW)		
SAMPLE RECEIVED ON	MONITORING AT		
SAMPLE COLLECTED BY	LABORATORY CHEMIST		
SAMPLING PROCEDURE	MANUFACTURER'S INSTRUCTION		
SAMPLE QUANTITY/PACKING	NOT APPLICABLE		

TEST REPORT					
LOCATION	UNIT	RESULT		LIMIT (INDUSTRIAL ZONE)	
		DAY TIME	NIGHT TIME	DAY TIME	NIGHT TIME
NEAR BOILER AND CHP	dB (A)	64	53	75	70
NEAR BRICK PLANT	dB (A)	72	62		
NEAR POWER PLANT	dB (A)	68	52		
NEAR ADMIN BUILDING	dB (A)	60	58		

**REMARKS: RESULTS ARE AS ABOVE**

### Terms & conditions

- > The report for publication, arbitration or as legal dispute is forbidden.
- > Test sample will be retained for 15 days after issue of test report unless otherwise agreed with customer.
- > This is for information as the party has asked for above.

 <b>REVIEWED BY</b>	 <b>For ULTIMATE ENVIROLYTICAL SOLUTIONS</b>	 <b>AUTHORIZED SIGNATORY</b>
------------------------	---	---------------------------------

-----End of the test report-----